

PERFORMANCE SPECIFICATION SHEET  
FUSES, INSTRUMENT, POWER, AND TELEPHONE  
(NONINDICATING), STYLE F10

This amendment forms a part of MIL-PRF-15160/10F, dated 12 October 1999, and is approved for use by all Departments and Agencies of the Department of Defense.

PAGE 3

VERIFICATION, delete in its entirety and substitute:

“VERIFICATION:

Qualification inspection is not applicable for characteristic B fuses of this specification sheet and is replaced by first article inspection which shall consist of Group A and Group B inspection of MIL-PRF-15160.

Qualification inspection (Characteristic A only): The number of qualification samples required shall be

- a. 24 samples maximum current rating of each voltage and design.
- b. 24 samples minimum current rating of each voltage and design.

NOTE: If labels are used, five additional samples of any rating are required.”

Cross-reference, delete “table V” and substitute “table II”.

PAGE 4

TABLE III, delete and substitute the following three Superseding numbers as indicated:

Change From:	Change To:
F10A250V 20A	F10A125V 20A
F10A250V 25A	F10A125V 25A
F10A250V 30A	F10A125V 30A

TABLE III, delete title and substitute: “ TABLE II. Cross reference.”

Custodians:

Army - CR  
Navy - SH  
Air Force - 11  
DLA - CC

Preparing activity:

DLA - CC  
(Project 5920-0738)

Review activities:

Army - AR, AT, CR4, MI  
Navy - AS, CG, MC, OS, YD  
Air Force - 19, 99