

PERFORMANCE SPECIFICATION SHEET

FUSES, STYLE F40

This amendment forms a part of MIL-PRF-15160/40A, dated 16 February 1998 and is approved for use by all Departments and Agencies of the Department of Defense.

PAGE 3

VERIFICATION, delete in its entirety and substitute:

“VERIFICATION:

Qualification inspection is not applicable for characteristic B fuses of this specification sheet and is replaced by first article inspection which shall consist of Group A and Group B inspection of MIL-PRF-15160.

Qualification inspection (Characteristic A only): The number of qualification samples required shall be:

- a. 24 samples maximum current rating of each voltage and design.
- b. 24 samples minimum current rating of each voltage and design.”

Custodians:  
Army - CR  
Navy - SH  
Air Force - 11  
DLA - CC

Review activities:  
Air Force - 99

Preparing activity:  
DLA - CC

(Project 5920-0740)