

PERFORMANCE SPECIFICATION SHEET

CIRCUIT BREAKERS, REMOTE CONTROL, AC, THERMAL, TRIP-FREE,  
SERIES TRIP, TRIPLE POLE, AUXILIARY CONTACTS (5 TO 100 AMPERES)

This amendment forms a part of MIL-PRF-83383/4D, dated 28 May 1999, and is approved for use by all Departments and Agencies of the Department of Defense.

PAGE 4

TABLE I, replace the maximum tripping time at 1000 percent rated current for the 20 ampere unit with 1.3 seconds.

Custodians:  
Army - CR  
Navy - AS  
Air Force - 11  
DLA - CC

Preparing activity:  
DLA - CC  
  
(Project 5925-0291)