

REVISIONS			
LTR	DESCRIPTION	DATE	APPROVED
A	Page 3 - Para. 3.4.5, added DWV requirement for -06 only, Para. 3.4.6, added insulation resistance requirement for -06 only.	12/12/84	I. R. Jones
A	Page 4 - Illustrated area to be free of protrusions and made other various changes.	12/12/84	I. R. Jones
A	Page 5 - Changed tolerances for dimensions B, C, D, and F. Designated weight as maximum.	12/12/84	I. R. Jones
A	Page 6 - Added 255 in-lbs torque for conduit nut.	12/12/84	I. R. Jones
A	Page 7 - Para. 3.5.5, added thermal shock testing requirement to Group B.	12/12/84	I. R. Jones
B	Page 6 - Change conduit nut from 8 to 6 point	12/12/84	I. R. Jones
C	Cancelled document	20 July 2000	K. A. Cottongim

DSCC DRAWING 83007 is cancelled without replacement as of 20 July 2000.

Previous Cage Code 14933 Superseded by 037Z3.

The original first page of this drawing has been replaced.

Prepared in accordance with MIL-STD-100

Selected item drawing

REV STATUS OF PAGES	REV	C																	
	PAGES	1																	

PMIC N/A	PREPARED BY Randy Larson	DEFENSE SUPPLY CENTER, COLUMBUS COLUMBUS, OH	
Original date of drawing 15 August 1983	CHECKED BY Randy Larson	TITLE FILTERS, POWER LINE FOR SHIELDED AREAS	
	APPROVED BY Ivan R. Jones		
	SIZE A	CODE IDENT. NO. 14933	DWG NO. 83007
	REV C		PAGE 1 OF 1